



"The Hose Company"

Date Ordered	05/11/15	Date Shipped	06/02/15
Customer Name	NAFECO	PO No.	270676 2-2
Work Order No.	300374	Invoice No.	304328
Description	5pcs of DP25-800-ECO-50-UL-ARN		

THIS IS TO CERTIFY THE FIRE HOSE SHIPPED ON THE ABOVE LISTED ORDER WAS HYDRO-STATICALLY TESTED WITH THE COUPLINGS ATTACHED. THE HOSE WAS INSPECTED AND TESTED TO THE REQUIREMENTS OF NFPA 1961 AND UL-19 STANDARDS.

Testing Inspector	BRANDON YOUNG		
Hydrostatic Test Pressure	800 PSI	Service Test Pressure	400 PSI
Number Accepted	5	Number Rejected	0

Date	06/16/15
-------------	-----------------

THIS IS TO CERTIFY THE HOSE WAS TESTED AND BOXED AS SPECIFIED ON THE ABOVE ORDER.

Shipping & Boxing Personnel	TERRY LAVINE
Approved for Shipment	LOUIS DEROSIER