



中国船级社
CHINA CLASSIFICATION SOCIETY
船用产品证书

证书编号/Certificate No.
SH19PPS00941_12

CERTIFICATE OF MARINE PRODUCT


兹证明本证书所列产品经本社署名验船师检验，符合本证书注明标准的要求。
This is to certify that the following products have been inspected by the undersigned surveyor of the Society and are found to comply with the requirements of the specified standards.

产品名称 Product	国际通岸接头 International Shore Connections
申请方 Applicant	上海莲盛消防器材厂 Shanghai Liansheng Fire-fighting Equipment Factory
制造厂 Manufacturer	上海莲盛消防器材厂 Shanghai Liansheng Fire-fighting Equipment Factory
订货方 Purchaser	
认可证书号/Certificate No. of Approval	SH16T00115-02
图纸批准号/Approval No. of Drawings	SH08A00400
用于/Intended for	船舶与海上设施/Ships and Offshore Installations
产品编号/Serial No.	2019001~2019050


产品检验标准/Product Inspection Standard

- 《国际消防安全系统规则》第2章
Chapter 2 of International Code for Fire Safety Systems

产品检验标志/Marking

位置/Position : 在产品上 / On the product
标志样式 :  钢印标志 / CCS steel stamp
Type of Marking

发证日期 2019年05月17日
Date of issue May. 17, 2019

验船师  Chen Xiaoyu
Surveyor

本证书根据中国船级社规范和相关规定签发。所有证书作为一个整体，必须同时使用。纸质证书每页均须由本社盖章方为有效，电子证书含数字签名方为有效。本证书复印件无效。任何单位和个人不应摘录或节选本证书的部分内容。有关方对所持证书的真实性有疑问时，可以向本社检验机构咨询。
This Certificate is issued pursuant to the Rules of the Society and related regulation. All pages of the certificate are taken as a whole and are used simultaneously. No paper certificate page is valid without hearing the stamp of the Society, no electronic certificates is valid without the digital signature, and no copied form of the certificate is regarded as valid. Any part of the certificate is not to be extracted or abridged by any unit or individual in any form. Related parties who are doubted about the authenticity of the certificate may inquire of the Society or its offices.

Form No: P01.1

联系方式/Contact Us. 见本社官方网站/See official web site of the Society (<http://www.ccs.org.cn>)



CCS
中国船级社

UTN: P019-269878

Nº 18690419

产品明细/Product Description**国际通岸接头/International Shore Connections (M001)**

名称/Name	属性(值)/Value	单位/Unit
型号/Type	D16050	
数量/Quantity	50	件/PCS
公称压力/Nominal Pressure	1.6	MPa
外径/Outer Diameter	178	mm
内径/Inner Diameter	64	mm
法兰厚度/Flange Thickness	≥14.5	mm
螺栓节圆直径/Bolt Circle Diameter	132	mm
螺栓及螺母/Bolts and Nuts	4副, 每只直径16mm, 长度50mm 4pieces, each of 16mm diam, 50mm in length	
法兰槽口/Slots In Flange	直径为19mm的孔4个, 等距离分布在上述螺栓节圆直径上, 开槽口至法兰盘外缘 4 holes 19 mm in diameter spaced equidistantly on a bolt circle of the above diameter, slotted to the flange periphery	
适用介质/Applicable Medium	淡水/海水 Fresh/Sea water	
材料/Material	ZCuZn16Si4	
试验压力/Test Pressure	2.4	Mpa

备注/Remarks

本社已审核了产品厂无石棉声明, 但本社的审核不免除产品厂按照合同关系向订货方保证产品无石棉的责任。

The declaration of asbestos-free submitted by manufacturer has been reviewed by the Society. However, liability of the manufacturer to guarantee the products are asbestos-free to purchaser under contract will not be exempted.

中国船级社上海分社
CCS Shanghai Branch