



"The Hose Company"

<b>Date Ordered</b>	<b>290279</b>	<b>Date Shipped</b>	<b>11/17/14</b>
<b>Customer Name</b>	<b>NORTH AMERICAN FIRE EQUIPMENT</b>	<b>PO No.</b>	<b>258931 2-6</b>
<b>Work Order No.</b>	<b>290285</b>	<b>Invoice No.</b>	<b>293735</b>
<b>Description</b>	<b>DP25-800-ECO-UL-50-ARN</b>		

**THIS IS TO CERTIFY THE FIRE HOSE SHIPPED ON THE ABOVE LISTED ORDER WAS HYDRO-STATICALLY TESTED WITH THE COUPLINGS ATTACHED. THE HOSE WAS INSPECTED AND TESTED TO THE REQUIREMENTS OF NFPA 1961 AND UL-19 STANDARDS**

<b>Testing Inspector</b>	<b>Brandon Young</b>		
<b>Hydrostatic Test Pressure</b>	<b>800 PSI</b>	<b>Service Test Pressure</b>	<b>400 PSI</b>
<b>Number Accepted</b>	<b>5</b>	<b>Number Rejected</b>	<b>0</b>

<b>Date</b>	<b>11/17/14</b>
-------------	-----------------

**THIS IS TO CERTIFY THE HOSE WAS TESTED AND BOXED AS SPECIFIED ON THE ABOVE ORDER.**

<b>Shipping &amp; Boxing Personnel</b>	<b>TERRY LAVINE</b>
<b>Approved for Shipment</b>	<b>LOUIS DEROSIER</b>



"The Hose Company"

<b>Date Ordered</b>	<b>290279</b>	<b>Date Shipped</b>	<b>11/17/14</b>
<b>Customer Name</b>	<b>NORTH AMERICAN FIRE EQUIPMENT</b>	<b>PO No.</b>	<b>258931 1-6</b>
<b>Work Order No.</b>	<b>290279</b>	<b>Invoice No.</b>	<b>294294</b>
<b>Description</b>	<b>DP15-800-ECO-UL-50-ARN</b>		

**THIS IS TO CERTIFY THE FIRE HOSE SHIPPED ON THE ABOVE LISTED ORDER WAS HYDRO-STATICALLY TESTED WITH THE COUPLINGS ATTACHED. THE HOSE WAS INSPECTED AND TESTED TO THE REQUIREMENTS OF NFPA 1961 AND UL-19 STANDARDS**

<b>Testing Inspector</b>	<b>Brandon Young</b>		
<b>Hydrostatic Test Pressure</b>	<b>800 PSI</b>	<b>Service Test Pressure</b>	<b>400 PSI</b>
<b>Number Accepted</b>	<b>10</b>	<b>Number Rejected</b>	<b>0</b>

<b>Date</b>	<b>11/17/14</b>
-------------	-----------------

**THIS IS TO CERTIFY THE HOSE WAS TESTED AND BOXED AS SPECIFIED ON THE ABOVE ORDER.**

<b>Shipping &amp; Boxing Personnel</b>	<b>TERRY LAVINE</b>
<b>Approved for Shipment</b>	<b>LOUIS DEROSIER</b>