



## MZQE.EX4211 Fire Hose, Lined, Uncoupled, for Municipal and Industrial Use

[Page Bottom](#)

---

### Fire Hose, Lined, Uncoupled, for Municipal and Industrial Use

[See General Information for Fire Hose, Lined, Uncoupled, for Municipal and Industrial Use](#)

**KEY FIRE HOSE CORP**

EX4211

2926 COLUMBIA HWY  
DOTHAN, AL 36303 USA

"Proflo" 1-1/2, 2, 2-1/2 and 3 in. nitrile rubber/polyvinyl chloride hose having a reinforcement of polyester filament synthetic warp threads and Polyamide nylon filament filler threads and nitrile/polyvinyl chloride cover judged equivalent to single-jacketed 250 psig service test pressure fire hose.

"Proflo" 4 and 5 in. nitrile rubber/polyvinyl chloride hose having a reinforcement of polyester filament synthetic warp threads and Polyamide nylon filament filler threads and nitrile/polyvinyl chloride cover judged equivalent to double-jacketed 200 psig service test pressure fire hose.

"DuraFlo" 1-3/4 and 2-1/2 in. nitrile rubber/polyvinyl chloride hose having a reinforcement of polyester filament synthetic warp threads and Polyamide nylon filament filler threads and nitrile/polyvinyl chloride cover judged equivalent to single-jacketed 250 psig service test pressure fire hose.

Single-jacketed fire hose, 1-1/2 in. size ("SP15"), 2 in. size ("SP20"), and 2-1/2 in. size ("SP25").

Double-jacketed fire hose, 1-1/2 in. size ("DP15"), 1-3/4 in. size ("DP17"), 2 in. size ("DP20"), 2-1/2 in. size \*("DP25"), 3 in. size ("DP30"), 3-1/2 in. size ("DP35"), and \*4 in. size ("DP40").

[Last Updated](#) on 2012-09-17

---

[Questions?](#)

[Print this page](#)

[Terms of Use](#)

[Page Top](#)

© 2015 UL LLC

When the UL Leaf Mark is on the product, or when the word "Environment" is included in the UL Mark, please search the [UL Environment database](#) for additional information regarding this product's certification.

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Certified and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Assemblies, Constructions, Designs, Systems, and/or Certifications (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2015 UL LLC".