



东台市江海救生消防设备有限公司
Dongtai City Jianghai Lifesaving & Fire-fighting
Equipment Limited Company

消防隔热服（防护服）产品合格证

Protective Clothing Quality Certificate

产品型号 Model	DTXF-93-I	型式认可证书 Certificate of Type Approval	NJ12T0047_05
制造年月 Date of manufacture	2015年6月	船用证书编号 Cert No. of product	TZ15P01160-01
产品编号 No	151172	规格 Size	S <input type="checkbox"/> M <input type="checkbox"/> L <input type="checkbox"/> XL <input checked="" type="checkbox"/>

主要指标 Performance

1	抗热辐射性能 Heat radiation resistance	在10KW/m ² 辐射热源下照射30秒后，其内表温度升高不大于25°C。 Under the heat radiation with 10KW/m ² the increase of temperature on inner-surface not over then 25°C after irradiate 30 seconds.
2	阻燃碳长（7）秒 Length of flame retarded carbon(7s)	<100mm
3	防水性能 Waterproof properties	≥4000 Pa
4	撕破强度 Tearing strength	≥32 N

本产品经检验合格，符合GA88
《消防隔热服性能要求及试验方法》、
《1974年国际海上人命安全公约2000修
正案》及《国际消防安全系统规则》的
要求，准予出厂。

It's in compliance with the
products of the SOLAS 1974 and it's
Amendments 2000 and International Code
for Fire Safety Systems and GA88.

检验员（签字）
Surveyor

吴 平

检验日期
Date of inspection

2015-6

www.dtjhsb.com