



昆山易美福机械设备有限公司

Kunshan EMF Industrial Co., Ltd.

江苏省昆山市新镇新浦路91号

91 Xinpu Road, Kunshan City, Jiangsu, China

电话(TEL): 0512-57113182 传真(FAX): 0512-57907599

Product Test Certificate

Product Name: fire angle valve 2-1/2"

Model No: EMF-0093N-00

Production standards: BS5154:1991

Qty: 45 pcs

Date: 02-12-2017

No. Test Item	Requirements & standards	Test Results
1. Material	Handwheel: Cast iron to BS1452	pass
	Valve body: BS2874 Hpb59-1	Pass
2. Measure & tolerance	Screw male thread 2-1/2" BSP	Pass
3. Appearance quality	scarless & without crack, good red Painting in surface	pass
4. Sealing performance	The process of sealing performance Test, each component should be able To withstand 1.6Mpa pressure, sustained 2 min can't appear leakage phenomenon	pass
5. Intensity	Water pressure test, adaptor should be able to withstand 2.4Mpa the pressure sustained 2min can't appear leakage phenomenon	pass

Checker: Coin Feng

Coin Feng

Recheck: Bryan Ho

Bryan Ho





昆山易美福机械设备有限公司

Kunshan EMF Industrial Co., Ltd.

江苏省昆山市新镇新浦路91号

91 Xinpu Road, Kunshan City, Jiangsu, China

电话(TEL): 0512-57113182 传真(FAX): 0512-57907599

Product Test Certificate

Product Name: fire valve globe straight 2-1/2"

Model No: EMF-0094N-00

Production standards: BS5154:1991

Qty: 38pcs

Date: 02-12-2017

No. Test Item	Requirements & standards	Test Results
1. Material	Handwheel: Cast iron to BS1452	pass
	Valve body: BS2874 Hpb59-1	Pass
2. Measure & tolerance	Screw male thread 2-1/2" BSP	Pass
3. Appearance quality	scarless & without crack, good red	
	Painting in surface	pass
4. Sealing performance	The process of sealing performance	
	Test, each component should be able	
	To withstand 1.6Mpa pressure, sustained	pass
	2 min can't appear leakage phenomenon	
5. Intensity	Water pressure test, adaptor should be able	
	to withstand 2.4Mpa the pressure sustained	pass
	2 min can't appear leakage phenomenon	

Checker: Coin Feng

冯凤

Recheck: Bryan Ho

何彬



昆山易美福机械设备有限公司

Kunshan EMF Industrial Co., Ltd.

江苏省昆山市新镇新浦路91号

91 Xinpu Road, Kunshan City, Jiangsu, China

电话(TEL): 0512-57113182 传真(FAX): 0512-57907599

Product Test Certificate

Product Name: fire angle valve 2"

Model No: EMF-0093B3-00

Production standards: BS5154:1991

Qty: 10 pcs

Date: 02-12-2017

No. Test Item	Requirements & standards	Test Results
1. Material	Handwheel: Cast iron to BS1452	pass
	Valve body: BS2874 Hpb59-1	Pass
2. Measure & tolerance	Screw male thread 2" BSP	Pass
3. Appearance quality	scarless & without crack, good red painting in surface	pass
4. Sealing performance	The process of sealing performance Test, each component should be able to withstand 1.6Mpa pressure, sustained 2 min can't appear leakage phenomenon	pass
5. Intensity	Water pressure test, adaptor should be able to withstand 2.4Mpa the pressure sustained 2 min can't appear leakage phenomenon	pass

Checker: Coin Feng

冯己东

Recheck: Bryan Ho

何建





昆山易美福机械设备有限公司

Kunshan EMF Industrial Co., Ltd.

江苏省昆山市新镇新浦路91号

91 Xinpu Road, Kunshan City, Jiangsu, China

电话(TEL): 0512-57113182 传真(FAX): 0512-57907599

Product Test Certificate

Product Name: fire valve globe straight 2"

Model No: EMF-0094B8-00

Production standards: BS5154:1991

Qty: 15 pcs

Date: 02-12-2017

No. Test Item	Requirements & standards	Test Results
1. Material	Handwheel: Cast iron to BS1452	pass
	Valve body: BS2874 Hpb59-1	Pass
2. Measure & tolerance	Screw male thread 2" BSP	Pass
3. Appearance quality	scarless & without crack, good red Painting in surface	pass
4. Sealing performance	The process of sealing performance Test, each component should be able To withstand 1.6Mpa pressure, sustained 2 min can't appear leakage phenomenon	pass
5. Intensity	Water pressure test, adaptor should be able to withstand 2.4Mpa the pressure sustained 2 min can't appear leakage phenomenon	pass

Checker: Coin Feng 冯飞

Recheck: Bryan Ho



何建



昆山易美福机械设备有限公司

Kunshan EMF Industrial Co., Ltd.

江苏省昆山市新镇新浦路91号

91 Xinpu Road, Kunshan City, Jiangsu, China

电话(TEL): 0512-57113182 传真(FAX): 0512-57907599

Product Test Certificate

Product Name: fire angle valve 1.5"

Model No: EMF-0093L-00A

Production standards: BS5154:1991

Qty: 5pcs

Date: 02-12-2017

No. Test Item	Requirements & standards	Test Results
1. Material	Handwheel: Cast iron to BS1452	pass
	Valve body: BS2874 Hpb59-1	Pass
2. Measure & tolerance	Screw male thread 1.5" BSP	Pass
3. Appearance quality	scarless & without crack, good red painting in surface	pass
4. Sealing performance	The process of sealing performance Test, each component should be able to withstand 1.6Mpa pressure, sustained 2 min can't appear leakage phenomenon	pass
5. Intensity	Water pressure test, adaptor should be able to withstand 2.4Mpa the pressure sustained 2min can't appear leakage phenomenon	pass

Checker: Coin Feng

冯时

Recheck: Bryan Ho

何进





昆山易美福机械设备有限公司

Kunshan EMF Industrial Co., Ltd.

江苏省昆山市新镇新浦路91号

91 Xinpu Road, Kunshan City, Jiangsu, China

电话(TEL): 0512-57113182 传真(FAX): 0512-57907599

Product Test Certificate

Product Name: fire valve globe straight 1.5"

Model No: EMF-0094M-00A

Production standards: BS5154:1991

Qty: 5pcs

Date: 02-12-2017

<u>No. Test Item</u>	<u>Requirements & standards</u>	<u>Test Results</u>
1. Material	Handwheel: Cast iron to BS1452	pass
	Valve body: BS2874 Hpb59-1	Pass
2. Measure & tolerance	Screw male thread 1.5" BSP	Pass
3. Appearance quality	scarless & without crack, good red Painting in surface	pass
4. Sealing performance	The process of sealing performance Test, each component should be able To withstand 1.6Mpa pressure, sustained 2 min can't appear leakage phenomenon	pass
5. Intensity	Water pressure test, adaptor should be able to withstand 2.4Mpa the pressure sustained 2min can't appear leakage phenomenon	pass

Checker: Coin Feng

冯进

Recheck: Bryan Ho

何进

